

# Evidence of Performance

Resistance to wind load

Watertightness, Air permeability

Operating forces, Load-bearing capacity of safety devices



## Test Report 103 24154/1e (ITT)

Translation of Test Report 103 24154/1 dated 24 August 2008

Client **DENIZPEN PLASTIK SAN. VE TIC. LTD. ŞTİ**  
Eski Edirne Yolu Selanik Cad. No: 23  
Kavaklı - Silivri

Istanbul  
Turkey

### Bases

EN 14351-1 : 2006-03

Test standards:

EN 1026 : 2000-06


EN 1027 : 2000-06

EN 12211 : 2000-06

EN 12046-1 : 2003-11

EN 14609 : 2004-03

### Representation



Product	Single tilt and turn window
Designation	P705
Overall dimensions (W x H)	750 mm x 1500 mm
Frame material	PVC-U / white
Special features	-/-

### Instructions for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1 : 2006-03. For the sake of clarity it may be used as the basis for the ITT report summary by the manufacturer in the framework of the attestation of conformity procedure 3 as the basis for the manufacturer declaration.

### Validity

The data and results refer solely to the tested and described specimen.

Subject to compliance with the relevant casement weights, the test results can be extrapolated for constructions of identical or smaller dimensions of the same design, type of rebate and similar format.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift test Documents" applies..

The cover sheet can be used as abstract.

### Contents

The report contains a total of 9 pages.

### Resistance to wind load – EN 12210



**Class C3/B3**

### Watertightness – EN 12208



**Class 8A**

### Air permeability – EN 12207



**Class 4**

### Operating forces – EN 13115



**Class 1**

### Load-bearing capacity of safety devices



**Requirement fulfilled**

ift Rosenheim  
24 August 2008

Jörn Peter Lass, Dipl.-Ing. (FH)  
Head of Testing Department  
ift Centre Windows & Facades

Benno Reichelt, Dipl.-Ing. (FH)  
Test engineer  
ift Centre Windows & Facades



ift Rosenheim GmbH

Geschäftsführer:  
Dipl.-Ing. (FH) Ulrich Sieberath  
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9  
D-83026 Rosenheim  
Tel.: +49 (0)8031/261-0  
Fax: +49 (0)8031/261-290  
www.ift-rosenheim.de

Sitz: 83026 Rosenheim  
AG Traunstein, HRB 14763  
Sparkasse Rosenheim  
Kto. 3822  
BLZ 711 500 00

Notified Body Nr.: 0757  
Anerkannte PUZ-Stelle: BAY 18  
DAP-PL-0988 09  
DAP-ZE-2288 00  
TGA-ZM-16-93-00  
TGA-ZM-16-93-60

