

**FUDEL**

FIRAT ENERJİ VE İNŞAAT LARABORATUVARI

T.C. MİLLÎ EĞİTİM BAKANLIĞI  
TS EN ISO/IEC 17025  
AB-0391-T

AB-0391-T

030715-02-01

07.15

**FUDEL**Fırat Conformity Assessment Laboratory  
Türkoba Mah. Pk.12 34907 Büyükçekmece-İstanbul**THERMAL CONDUCTIVITY STATEMENT**

<b>Customer</b>	Fırat Plastik ve Kauçuk San. Tic. A.Ş. AR-GE Müdürlüğü Türkoba Mah. Fırat Plastik Cad. No: 23 34537 Büyükçekmece - İstanbul
<b>Product Description Size (wxh)</b>	FIRATPEN / HOLLANDA FRAME TILT AND TURN WINDOW (750×1500)

**THERMAL CONDUCTIVITY COEFFICIENT VALUE ( TS EN 10077-1:2007 )****1,02 W/m<sup>2</sup>K**

*This statement belongs only to the sample for which the calculation has been carried out.*

*This report cannot be copied and reproduced in part without the written approval of the laboratory.*

*Reports without signature and stamp are invalid.*

**Date of Sample Acceptance: 30.12.2017****Test Period: 02.01.2018 - 02.01.2018****Date of Approval: 02.01.2018**

Uğur KABAK

Laboratorian / Technical Administrator

Test Supervisor

Bayram KARA

Technical Administrator / Quality Manager

Approval